

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No.F6/DFS/MS/School/2021/ 437

Dated: 6 /07/2021

**FIRE SAFETY CERTIFICATE**

Certified that the Building Shree Venkateshwar International School, Located at Sector 18, Dwarka, New Delhi 110075 comprised of Basement + Ground + 3 Upper Floor was issued FSC vide Letter No. F6/DFS/MS/School/2018/SZ/1146 Dated 18/05/2018. The premises was re inspected by the officers concerned of this department on 21-06-2021 in the presence of Sh. Shalender Solanki (Chairman) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class-B "Educational" with effect from 6/7/21 for a period of three years

Issued on 6/7/21 at New Delhi by.

  
(Sunil Chaudhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

**Copy to:**

1. The Principal Shree Venkateshwar International School, Located at Sector 18, Dwarka, New Delhi 110075.
2. Directorate of Education Old Secretariat Delhi - 110054.
3. The Vice Chairman, DDA, Vikas Sadan INA, Delhi-23.

**Following fire safety directives must be adhered to:-**

- 1 Two temporary rooms are seen at terrace. The Rooms shall not be used for school activities.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 3 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 4 The trained staff should be available round the clock.
- 5 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 6 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 7 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 8 Basement shall be used strictly as per building bye laws.
- 9 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).