

"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"



DELHI JAL BOARD (GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
TRANS YAMUNA REGION TAHIRPUR DELHI-110093



NO: DJB/ACWA(TYR)/2022.....

ACWA-TYR

Diary No. 1336 dt 23.3.2022

DATE:- 14-03-2022

Analysis report of DJB supply water samples collected from Arwachin Bharti Bhawan Sr. Sec. School, C-Block, Vivek Vihar, Delhi -95 (1) Inlet and (2) Outlet For Drinking Purpose.

Ref. No.:- ABB/SSS/VV/6328/2022

Date of collection:- 08-03-2022

Challan No:-292

dated:- 04-03-2022

S. No.	PARTICULARS	BIS:10500-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(1)	(2)
A.	Physical Examination					
1.	Colour	-	Clear	Clear
2.	Odour	-	Chlor.	Chlor.
3.	Turbidity	1.0	5.0	NTU	2.92	3.07
4.	pH Value	6.5-8.5	--	-	7.5	7.6
5.	Electrical Conductivity	--	--	µs/cm	238	196
6.	Total Dissolved Solids	500	2000	mg/l	154	127
B.	Chemical Examination					
7.	P th Alkalinity	45	NO RELAXATION	mg/l	NIL	NIL
8.	Total Alkalinity	200	600	mg/l	70	60
9.	Total Hardness	200	600	mg/l	94	90
10.	Calcium Hardness	mg/l	56	48
11.	Magnesium Hardness	mg/l	38	42
12.	Calcium as (Ca)	75	200	mg/l	22.4	19.2
13.	Magnesium as (Mg)	30	100	mg/l	9.12	10.08
14.	Ammonical Nitrogen	0.5	NO RELAXATION	mg/l	N.D	N.D
15.	Nitrite	mg/l	N.D	N.D
16.	Nitrate	45	NO RELAXATION	mg/l	2.55	3.31
17.	Sulphate	200	400	mg/l	79.4	66.4
18.	Chloride	250	1000	mg/l	20	12
19.	Fluoride	1.0	1.5	mg/l	0.67	0.49
20.	Total Iron	1.0	NO RELAXATION	mg/l	0.10	0.20
21.	Cyanide	0.05	NO RELAXATION	mg/l	N.D	N.D
22.	Residual Chlorine	0.2	1.0	mg/l	0.50	0.25
C.	Bacteriological Examination					
23.	Coliform count	Absent	NO RELAXATION	MPN/100ml	0	0

This Report Pertains To The Particular Sample Only

REMARKS:- On the basis of above tested parameters, water samples conforms BIS: 10500-2012 and can be considered fit for drinking purpose.

[Signature]
14/03/22
A/CHEMIST

[Signature]
14/3/22
CHEMIST

[Signature]
14.3.2022
ACWA (TYR)

Asst. Chief Water Analyst
D.J.B. Govt. of N.C.T. of Delhi
Quality Control Zonal Laboratory (TyR)
Tahir Pur Dilshad Garden, Delhi-93

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**


No. F.6/DFS/MS/School/2021/NDZ/ 849

Dated: 13/10/2021

FIRE SAFETY CERTIFICATE

Certified that the Arwachin Bharti Bhawan Sr. Sec. School at C-Block, Vivek Vihar, Delhi-110095 comprised of two blocks the first block basement, ground plus two upper floors & second block ground plus three upper floors owned/occupied by Arwachin Bharti Bhawan Sr. Sec. School was issued FSC vide letter No. F.6/DFS/MS/School/2018/NDZ/1648 dated 16/07/2018. The school building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 30/09/2021 in the presence of Mr. Ravi Chauhan, Caretaker of the school and that the school building is fit for occupancy class "B" 'Educational Building' with effect from 13/10/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf.

Issued on 13/10/2021 at New Delhi by


(Dr. S. K. Tomar)
Dy. Chief Fire Officer

To,

The Principal,
Arwachin Bharti Bhawan Sr. Sec. School,
C-Block, Vivek Vihar, Delhi-110095

Copy to:-

1. The Commissioner,
EDMC, Headquarters,
419, Udyog Sadan, Patparganj Industrial Area,
New Delhi-110092
2. The Dy. Director of Education,
D-Block, Anand Vihar, Delhi

Municipal Corporation of Delhi
Public Health Department
Shahdara (South) Zone
419, First Floor, Udyog Sadan,
Patparganj Industiral area, Delhi-110092

No. DHO/Shah.(S)/2022/D-326

Dated:- 14/7/22


School Health Certificate

1. Name of School	: Arwachin Bharti Bhawan Sr. Sec. School
2. Location of the School	: C Block, Vivek Vihar, Delhi-110095
3. No. of Staff	: 136
4. No. of Students	: 3947
5. No. of Rooms	: 163
6. No. of Doors In each room	: 01
7. No. Windows In each room	: 06
8. No. of Desk & Chair	: Provided in each room
9. Building Structure	: Pucca
10. No. of Urinals for Boys	: 62
11. No. of Urinals for Girls	: 26
12. No. of Urinals of Handicapped	: 22
13. No. of General Toilets	: 08
14. Drinking Water	: Provided
15. Electricity	: BSES Supply

At the time of inspection, school is found running under sanitary and hygiene conditions. This certificate has no bearing on unauthorized construction of the premises if any and on any dispute regarding title of land.

This certificate/NOC is valid for (01) one year only.

The Principal,
Arwachin Bharti Bhawan Sr. Sec. School
C Block, Vivek Vihar, Delhi-110095


Deputy Health Officer
Shahdara (South) Zone
DEPUTY HEALTH OFFICER
MUNICIPAL CORPORATION OF DELHI
SHAHDARA (SOUTH) ZONE