



**DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT NANGLOI , DELHI-110041**



Water sample collected from " Green View Public School" Dwarka Vihar (Nr. Sec-16 B Dwarka) Kakrola Road Najafgarh New Delhi -110043 vide challan No- 197 Dated- 13.10.2022 .

S. No	Parameter	Units	Limit		S1
			Acceptable	Permissible	
PHYSICAL EXAMINATION					
1.	Date of collection	-----	--	--	18.10.2022
2.	Date of Analysis	-----	--	--	19.10.2022
3.	Colour	Hazen	5.0	15	Clear
4.	Odour	-----	No. Objectionable		No Obj
5.	Turbidity	N.T.U.	1.0	5.0	1.28
6.	PH value	-----	6.5	8.5	7.4
7.	Electrical Conductivity	µmho	--	--	295
8.	Total dissolved solids	mg/l	500	2000	145
CHEMICAL EXAMINATION					
9.	P th Alkalinity	mg/l	--	--	NIL
10.	Total Alkalinity	mg/l	200	600	80
11.	Total Hardness	mg/l	200	600	120
12.	Calcium Hardness	mg/l	--	--	78
13.	Magnesium Hardness	mg/l	--	--	42
14.	Calcium as Ca	mg/l	75	200	31.2
15.	Magnesium as Mg	mg/l	30	100	10.08
16.	Ammonia as N	mg/l	0.5	N.R.	NIL
17.	Nitrite as N	mg/l	---	--	NIL
18.	Nitrate as No ₃	mg/l	45	N.R.	3.4
19.	Sulphate	mg/l	200	400	36
20.	Chloride	mg/l	250	1000	22
21.	Dissolved Iron	mg/l	0.3	N.R.	0.06
22.	Fluoride	mg/l	1	1.5	0.04
23.	Cyanide	mg/l	0.05	N.R.	ND
24.	Residual Chlorine	mg/l	0.20	1.0	0.25
BACTERIOLOGICAL EXAMINATION					
25.	Coli-form per 100 ml at 37°C	MPN	0		0

REMARKS : As per tested parameters sample -S1 can be use for drinking purpose.


S. Pandey
Chemist

S. Pandey
ACWA
Asstt. Chief Water Analyst
DELHI JAL BOARD
Govt. of N.C.T. Delhi



MUNICIPAL CORPORATION OF DELHI

OFFICE OF THE DY. HEALTH OFFICER : NAJAFGARH ZONE
ROOM NO.408, 4TH FLOOR, ZONAL BUILDING, DHANSA STAND,
NAJAFGARH, NEW DELHI 110043



No.DHO/NGZ/2022/ 3263

Dated 29/11/22

1. Name of the School **GREEN VIEW PUBLIC SCHOOL**
2. School Address **DWARKA VIHAR (NEAR SECTOR-16B), KAKROLA ROAD NEW DELHI-110043.**
3. No. of Shift ONE Timing 8:00 AM TO 02:00 PM
4. No. of Students: Boys =897 Girls 589 Total =1,486
5. No. of Staffs: Male 09 Female 46 Total = 55

Details of Accommodations present in School

1. Floor Space in the Classroom Sufficient/insufficient **SUFFICIENT**
2. The Classrooms are Well Lighted/ ill lighted **WELL LIGHTED**
3. The Classrooms are Well Ventilated/ ill ventilated **WELL VETILATED**
4. The Classrooms are kept / Not kept Neat & Clean: **NEAT AND CLEAN**
5. The Classrooms/Building requires/ do not required Whitewash etc. **NOT REQUIRED**
6. The Drinking Water is Wholesome/ not wholesome **WHOLESOME**
7. The Latrine arrangement is Sanitary/ insanitary **SANITARY FROM HEALTH POINT OF VIEW.**

No. of toilets seats for student

1. One latrine-cum-urinal is required for 25 female student, so total is **SUFFICIENT**
2. One latrine for 40 male student is required so total is **SUFFICIENT**
3. Separate Toilet arrangement for staff present: Yes/No **YES SEPARATE EXISTS FOR STAFF.**
4. The Overall facilities: Good/ Adequate/Inadequate V.**GOOD FROM HEALTH POINT OF VIEW AND VALID UP TO ONE YEAR FROM ISSUANCE DATE.**

If Building Department or any other Govt. agency takes actions against u/a constructions or any dispute, then the Health Certificate will be stand cancelled/revoked without any further intimation in this regard.

(Remark: Certificate is valid for one year)


Deputy Health Officer
Najafgarh Zone
Deputy Health Officer
Najafgarh Zone, MCD